

C A M B R I D G E  
**FIRE**RESEARCH

**REPORT NUMBER**  
**CFR1606031**

**FIRE RESISTANCE TEST**  
**IN ACCORDANCE WITH BS476: Part 22: 1987**

**Sponsor:** Exitex Limited  
**Address:** Mountpleasant  
Dundalk  
County Louth  
Ireland  
**Date of test:** 3<sup>rd</sup> June 2016

**Results:**

Left hand doorset

Test duration: 37 minutes  
Integrity: 36 minutes  
Insulation: 36 minutes

Right hand doorset

Test duration: 37 minutes  
Integrity: 33 minutes  
Insulation: 33 minutes



**Summary of test specimen:**

Two single acting single leaf doorsets comprising Jeld Wen door blanks, tested unlatched.

Left hand leaf size:  
2040 high x 926 wide x 44 thick overall

Right hand leaf size:  
2040 high x 925 wide x 44 thick overall



## 0 CONTENTS PAGE

|   |    |
|---|----|
| 0 CONTENTS PAGE .....   | 2  |
| 1 PREPARATION FOR TESTING .....   | 3  |
| 1.1 Specimen conditioning .....   | 3  |
| 1.2 Associated construction .....   | 3  |
| 1.3 Specimen construction .....   | 3  |
| 1.4 Specimen verification .....   | 3  |
| 1.5 Specimen installation and fixity .....                                | 3  |
| 1.6 Specimen selection .....  | 3  |
| 2 PRE-TEST MEASUREMENTS AND SETTING .....                                 | 4  |
| 2.1 Gap measurements .....  | 4  |
| 2.2 Closer force measurement .....  | 6  |
| 3 TEST CONDITIONS, INSTRUMENTATION AND MEASURING .....                    | 7  |
| 3.1 Furnace temperature .....   | 7  |
| 3.2 Furnace pressure .....  | 8  |
| 3.3 Ambient temperature .....   | 8  |
| 3.4 Unexposed face specimen thermocouples .....                           | 9  |
| 3.5 Deflection .....  | 11 |
| 4 TEST OBSERVATIONS .....   | 13 |
| 5 LIMITATIONS .....   | 15 |
| APPENDIX 1 SPECIMEN CONSTRUCTION .....                                    | 16 |
| Appendix 1 Table 1a Left hand Leaf .....                                  | 16 |
| Appendix 1 Table 1b Right hand Leaf .....                                 | 20 |
| Appendix 1 Figure 1 – Elevation left hand doorset – unexposed face .....  | 23 |
| Appendix 1 Figure 2 – Section A – A .....                                 | 24 |
| Appendix 1 Figure 3 – Section B – B .....                                 | 24 |
| Appendix 1 Figure 4 – Section C – C .....                                 | 25 |
| Appendix 1 Figure 5 – Elevation right hand doorset – unexposed face ..... | 26 |
| Appendix 1 Figure 6 – Section D – D .....                                 | 27 |
| Appendix 1 Figure 7 – Section E – E .....                                 | 27 |
| Appendix 1 Figure 8 – Section F – F .....                                 | 28 |
| APPENDIX 2 PHOTOGRAPHS .....  | 29 |
| Appendix 2.1 Pre-test photos .....  | 29 |
| Appendix 2.2 During test photos .....                                     | 32 |
| Appendix 2.3 Post test photos .....                                       | 35 |
| APPENDIX 3 POSITIONING OF INSTRUMENTATION .....                           | 36 |
| APPENDIX 4 RECORDED THERMOCOUPLE DATA .....                               | 37 |

## **1 PREPARATION FOR TESTING**

### **1.1 Specimen conditioning**

The specimen components were at Cambridge Fire Research for a total period of 1 days, during which time they were stored, surveyed and prepared for testing. During this period the temperature and relative humidity were measured and recorded to be within the range of 13 to 16°C and 70 to 77% respectively.

### **1.2 Associated construction**

Cambridge Fire Research constructed a timber stud partition with a layer of 12.5mm British Gypsum FireLine board to the unexposed face and a layer of 15mm British Gypsum FireLine board to the exposed face. This provided two apertures, the left hand aperture was 2072 mm high x 1007 mm wide and the right hand aperture was 2071 mm high x 1005 mm wide.

In accordance with Fire Test Study Group Resolution No. 51 continuity of the threshold was simulated by the installation of a solid non-combustible threshold extension by Cambridge Fire Research, such that the extension was flush with the threshold onto which the specimen was positioned.

### **1.3 Specimen construction**

The specimens were supplied complete by the sponsor.

### **1.4 Specimen verification**

Cambridge Fire Research carried out a detailed survey of the specimens to verify the information provided by Sponsor. This included verifying the weight, densities, materials and dimensions of construction components wherever possible.

Details and drawings of the construction are shown in Appendix 1.

Photographs of details of the construction taken before the test are shown in Appendix 2.

### **1.5 Specimen installation and fixity**

The sponsor installed the specimens into the associated construction. The specimens were asymmetrical and fitted such that the doors opened towards the heating conditions of the test. The doorsets were unlatched prior to the start of the test.

### **1.6 Specimen selection**


Cambridge Fire Research was not involved in any selection or sampling procedures for the tested specimen. The sponsor declared that the intumescent strips FO104 and FO154 were sampled by Certifire.

## 2 PRE-TEST MEASUREMENTS AND SETTING


### 2.1 Gap measurements

The gap between the leaf edges and the frame and at the threshold was measured on the exposed face prior to the start of the test. The following figures show the position at which the measurements were made and the recorded gap (mm) at those positions.

Left hand doorset:



Right hand doorset:



## 2.2 Closer force measurement

The door opening and closing forces for both leaves were measured in accordance with Fire Test Study Group Resolution No. 63 and the calculated moments are shown in the following tables.

Left hand doorset:

| Direction                          | Closing force (N) | Closing moment (Nm) | Opening force (N) | Opening moment (Nm) |
|------------------------------------|-------------------|---------------------|-------------------|---------------------|
| Opening towards heating conditions | 29.0              | 21.8                | 57.2              | 42.9                |


Right hand doorset:

| Direction                          | Closing force (N) | Closing moment (Nm) | Opening force (N) | Opening moment (Nm) |
|------------------------------------|-------------------|---------------------|-------------------|---------------------|
| Opening towards heating conditions | 30.3              | 22.7                | 55.9              | 41.9                |

### 3 TEST CONDITIONS, INSTRUMENTATION AND MEASURING


#### 3.1 Furnace temperature

Furnace temperature was controlled so as to follow the standard temperature/time curve defined in the test standard and within the tolerances permitted. The furnace mean temperature was calculated from the output recorded using nine furnace thermocouples of the design specified in the test standard. The following graph shows the standard and mean furnace temperature/time data.



### 3.2 Furnace pressure

Furnace pressure was maintained for the duration of the test at a nominal + 13.0 Pa measured at the pressure sensing head. When a linear pressure gradient of 8.5 Pa/m is applied this equates to + 0 Pa at 1 m above the notional floor level. The furnace pressure was controlled within the tolerances permitted in the test standard. The following graph shows the actual and desired furnace pressure/time data.



### 3.3 Ambient temperature

Ambient temperature at the start of the test was 14°C.  
Ambient temperature remained at 14°C during the test.



### 3.4 Unexposed face specimen thermocouples

Surface temperature measuring thermocouples of the design specified in the test standard were affixed to the unexposed face of the specimens to monitor the temperature rise as follows:

Left hand doorset:

|       |                    |                  |
|-------|--------------------|------------------|
| Leaf  | Channels 16 to 20  | (mean & maximum) |
|       | Channels 24 and 25 | (maximum only)   |
| Frame | Channels 21 to 23  | (maximum only)   |

Right hand doorset:


|       |                    |                  |
|-------|--------------------|------------------|
| Leaf  | Channels 26 to 30  | (mean & maximum) |
|       | Channels 34 and 35 | (maximum only)   |
| Frame | Channels 31 to 33  | (maximum only)   |

The positions of these thermocouples are shown in Appendix 3.

A roving thermocouple was available for measurement of any specific hotspots and was recorded on Channel 15.

The recorded data of all individual thermocouples is shown in the tables in Appendix 4.


The following time/temperature graph shows the mean leaf temperatures.




3.5 Deflection

Taut stainless steel wires were anchored horizontally across the unexposed face of the specimens such that any deflection experienced by the test specimens could be measured. One wire was positioned 10 mm vertically below the head of the leaves, the second at mid-height and the third 10 mm vertically above the threshold. The following figure shows these positions with the elapsed time (minutes) in the left hand column and the recorded deflection (mm) in the right hand column. Positive values indicate deflection towards the heating conditions of the test.

Left hand doorset:



Right hand doorset:



## 4 TEST OBSERVATIONS

### Left hand doorset:

Photographs taken during the test are shown in Appendix 2.

| (E = Exposed face: U = Unexposed face) |      |   |
|--|------|---|
| Time<br>(min:sec)                      | Face | Observation   |
| 00:00                                  |      | Start of the test.  |
| 05:30                                  | U    | Smoke/steam issues at the closing stile/head corner.  |
| 12:00                                  | U    | Smoke/steam at top corners of frame/partition interface.  |
| 13:00                                  | E    | Closer detaches.  |
| 13:15                                  | U    | Smoke/steam issues at both top corners.   |
| 14:00                                  | E    | Majority of facing has detached and core is fissured.   |
| 24:30                                  | U    | Smoke/steam decreasing at top corners.  |
| 28:25                                  | U    | Smoke/steam issuing at centre hinge position.   |
| 32:00                                  | U    | Fielded regions starting to discolour at various locations.<br>Smoke/steam increasing at centre hinge position and fielded regions. |
| 36:00                                  | U    | Glow at both top corners.   |
| 36:23                                  | U    | Flaming commences at the head of the leaf.  |
| 36:33                                  | U    | <b>INTEGRITY FAILURE</b> due to sustained flaming.<br><b>INSULATION FAILURE</b> due to integrity failure.                           |
| 37:32                                  |      | The test is terminated.   |

### Right hand doorset

Photographs taken during the test are shown in Appendix 2.

| (E = Exposed face: U = Unexposed face) |      |   |
|--|------|---|
| Time<br>(min:sec)                      | Face | Observation   |
| 00:00                                  |      | Start of the test.  |
| 05:00                                  | U    | Smoke/steam issues at the closing stile/head corner.  |
| 12:10                                  | U    | Aluminium on threshold at closing stile.  |
| 12:35                                  | U    | Smoke/steam issues at hanging stile/head corner but is decreasing generally.                              |
| 13:30                                  | U    | Leaf to stop gap at bottom of closing stile is nominally 12mm.  |
| 15:00                                  | E    | Handle missing, facing missing and core is fissured.  |
| 20:00                                  | U    | Leaf surface coating bubbling at closing stile/head corner and 300mm down closing stile.                  |
| 28:00                                  | U    | Smoke/steam issuing at centre hinge position.   |
| 31:55                                  | U    | Expanded intumescent visible at bottom of closing stile.  |
| 32:18                                  | U    | Glow at hanging stile/head corner.  |
| 32:41                                  | U    | Fissuring at top right hand corner of left hand centre panel.   |
| 33:22                                  | U    | Glow at top right hand corner of left hand centre panel.  |
| 33:37                                  | U    | Flaming commences at the top right hand corner of left hand centre panel.                                 |
| 33:47                                  | U    | <b>INTEGRITY FAILURE</b> due to sustained flaming.<br><b>INSULATION FAILURE</b> due to integrity failure. |
| 35:10                                  | U    | Flaming commences at bottom left hand panel.  |
| 35:20                                  | U    | <b>Further integrity failure</b> due to sustained flaming.  |
| 37:32                                  |      | The test is terminated.   |

## 5 LIMITATIONS

1. The test results relate only to the specimens tested. Appendix A of BS476: Part 22: 1987 provides guidance information on the application of fire resistance tests and the interpretation of test data. Application of the results to specimens of different dimensions, orientation or incorporating different components should be the subject of a design appraisal or further testing.
2. The results relate only to the behaviour of the specimens of the element of construction under the particular conditions of test. They are not intended to be the sole criteria for assessing the potential fire performance of the element in use, nor do they reflect the actual behaviour in fires.
3. The doorsets were asymmetrical and were tested such that the door leaves opened towards the heating conditions of the test. The test results may not be appropriate to situations where the door leaves open away from the heating conditions.

|   |
|---|
| <p><b>This report is the property of the test sponsor and may not be reproduced or passed to a third party without their prior agreement.</b></p> |
|---|

Report prepared by:



**E Southern**  
Deputy Head of Testing

Report checked by:



**E Wilson**  
Head of Testing

Report issued: 12<sup>th</sup> July 2016

## APPENDIX 1 SPECIMEN CONSTRUCTION

The item numbers listed in Appendix 1 Table 1 are shown in the figures in Appendix 1 refer to the components of the specimen construction. Any photo numbers refer to those in Appendix 2.

Please note that unless otherwise indicated the following applies:

- All dimensions and materials of construction were verified by the laboratory.
- Figures are not to scale.
- All dimensions are given in mm.

### Appendix 1 Table 1a Left hand Leaf

| Item | Component   | Information  |
|------|---|--|
| 1L   | <b>Door frame</b><br>Supplier:<br>Description:<br><br>Fixing to supporting construction:<br><br>Density (kg/m <sup>3</sup> ):<br>Overall size (h x w x d):<br>Cross section size (h x d):   | Exitex Limited.<br>A 3 sided MDF frame with horizontal rebate joints at the top corners fixed with 2 No. Ø5 x 80 countersunk woodscrews at 65 centres and PVA adhesive**. 5 No. No.10 x 3" countersunk woodscrews set 200 from top and 140 from bottom with the remaining 3 No equally spaced on the jambs.<br>720 minimum**<br>2077 x 992 x 100<br>30 x 100                                 |
| 2L   | <b>Stops</b><br>Supplier:<br>Description:<br><br>Density (kg/m <sup>3</sup> ):<br>Overall size (w x d):   | Exitex Limited.<br>Butt jointed MDF stops fixed with 38mm x 16swg brads at 200* centres.<br>720 minimum**<br>12 x 31   |
| 3L   | <b>Leaf</b><br>Supplier:<br>Manufacturer:<br>Type:<br><br>Description:<br><br>Overall size (h x w x t):<br>Weight (kg):<br>Sub-components:<br>Core:<br>Type:<br>Overall size((h x w x t):<br>Top/bottom rail - inner:<br>Description: | Exitex Limited.<br>Jeld Wen<br>F30RRO BTN 2040x926 MZF1 11/05/16 CF160 A4499704<br>6 panel FD30 leaf with moulded skins as shown in Figures 1 to 4.<br>2040 x 926 x 44 (to 23 at fielded area)<br>38.2 (with ironmongery)<br><br>Particle board** machined to form panel profiles.<br>1896 x 860 x 38<br><br>Particle board** oriented 90° to core and adhered to core using PVA adhesive**. |



| Item                     | Component  | Information   |
|--------------------------|--|---|
| <b>3L</b><br><b>cont</b> | <p>Overall size (h x w x t):<br/>Density (kg/m<sup>3</sup>):<br/>Top/bottom rail - outer:<br/>Description:</p> <p>Overall size (h x w x t):<br/>Density (kg/m<sup>3</sup>):<br/>Stiles:<br/>Description:<br/>Overall size (h x w x t):<br/>Density (kg/m<sup>3</sup>):<br/>Moulded skin:<br/>Description:<br/>Thickness (t):<br/>Density (kg/m<sup>3</sup>):</p> | <p>35± x 860 x 38<br/>Not declared*</p> <p>Softwood** adhered to inner rail using PVA adhesive**.</p> <p>27±x 860 x 38<br/>Not declared*</p> <p>Softwood** adhered to core using PVA adhesive**.</p> <p>2040 x 34 x 38 hanging<br/>2040 x 32 x 38 closing<br/>Not declared*</p> <p>Hardboard** adhered to core using PVA adhesive**.</p> <p>3<br/>Not declared*</p>                                 |
| <b>4L</b>                | <p><b>Hinges</b><br/>Manufacturer:<br/>Type:</p> <p>Material:<br/>Number:<br/>Location:</p> <p>Blade size (h x w x t):<br/>Knuckle size (Ø):<br/>Fixings (Ø x l):</p>  | <p>Hoppe<br/>Arrone AR8582-SSS butt hinge with concealed bearings.<br/>Stainless steel.<br/>3<br/>Set at 150, 930 and 1708 from the top of the leaf to the top of the blade.<br/>102 x 29 x 3.<br/>13.5.<br/>4 No Ø4.9 x 30 countersunk stainless steel wood screws per blade.</p>  |
| <b>5L</b>                | <p><b>Closer</b><br/>Manufacturer:<br/>Reference:<br/>Description:</p> <p>Overall size (l x h x d):</p>  | <p>Hoppe<br/>Arrone size 3 AR 450 SE<br/>A scissor arm closer with mild steel arms and aluminium body incorporating steel components fitted to the exposed face of both leaves positioned in accordance with the manufacturer's instructions using 2No. Ø4.8 x 27 long steel pan head screws to the frame and 4No.Ø5.4 x 32 long steel raised countersunk screws to the leaf.<br/>180 x 44 x 64</p> |
| <b>6L</b>                | <p><b>Latch</b><br/>Supplier:<br/>Part Number:<br/>Description:</p>  | <p>Zoo Hardware Ltd<br/>CE1121<br/>A mainly steel cylinder mortice latch fitted central to the leaf depth such that the centre line of the spindle is 950 above the bottom of the leaf and affixed through the steel forend using 2No. steel countersunk woodscrews. A steel strike was fitted to</p>   |

| Item                     | Component   | Information  |
|--------------------------|---|--|
| <b>6L</b><br><b>cont</b> | <p>Overall size:</p> <p>Body (h x w x d):</p> <p>Forend (h x d x t):</p> <p>Forend cover (h x d x t):</p> <p>Strike (h x d x t):</p> <p>Strike box (h x w x d):</p> | <p>the jamb to suit the position of the latch and affixed using 2No. steel raised countersunk woodscrews.</p> <p>23 x 60 x 15</p> <p>60 x 21.5 x 1.5</p> <p>60 x 25 x 1.1</p> <p>65 x 41 x 1.1, including a tongue of 40 x 16.</p> <p>58 x 14 x 23.5 plastic</p> |
| <b>7L</b>                | <p><b>Handleset</b></p> <p>Manufacturer:</p> <p>Reference:</p> <p>Description:</p> <p>Overall Size:</p> <p>Handle (h x w x l):</p> <p>Rose cover (Ø x d x t):</p>   | <p>M Marcus</p> <p>Steel Line SS-601-S</p> <p>Square section tube lever handle, stainless steel. Affixed to leaf with 2No. countersunk steel screws through backplate and 2No. through screws.</p> <p>19 x 19 x 133</p> <p>54 x 8 x 1</p>                        |
| <b>8L</b>                | <p><b>Automatic door bottom</b></p> <p>Supplier:</p> <p>Reference:</p> <p>Description:</p> <p>Overall Size (h x w x d):</p>   | <p>Exitex Limited</p> <p>Concealex</p> <p>Surface mounted automatic door bottom with aluminium body and elastomeric seal fixed with 2 No. steel screws according to manufacturer's instructions to the unexposed side of the leaf.</p> <p>39 x 900 x 13</p>      |
| <b>9L</b>                | <p><b>Intumescent – frame</b></p> <p>Manufacturer:</p> <p>Reference:</p> <p>Description:</p> <p>Location:</p> <p>Overall Size:</p>                                  | <p>Exitex Limited</p> <p>FO154</p> <p>A strip of graphite-based intumescent in a PVC casing with self-adhesive tape on one side. It is fully interrupted at the hinges and at the strike.</p> <p>Positioned 14mm from exposed face.</p> <p>15 x 4</p>            |
| <b>10L</b>               | <p><b>Intumescent – hinge</b></p> <p>Supplier:</p> <p>Reference:</p> <p>Description:</p> <p>Overall size (t):</p>   | <p>Exitex Limited</p> <p>Exi-Fire hinge pads</p> <p>A graphite based intumescent fitted beneath each blade</p> <p>1</p>  |
| <b>11L</b>               | <p><b>Intumescent – latch</b></p> <p>Supplier:</p> <p>Reference:</p> <p>Description:</p> <p>Overall size (t):</p>   | <p>Exitex Limited</p> <p>Exi-Fire latch protection</p> <p>A graphite based intumescent wrapped around body of latch.</p> <p>1</p>  |

| Item | Component   | Information  |
|------|---|--|
| 12L  | <b>Intumescent – strike and forend</b><br>Supplier:<br>Reference:<br>Description:<br><br>Thickness (t):                               | Exitex Limited<br>Exi-Fire<br>A graphite based intumescent under strike and forend and wrapped around body of strike box.<br>1   |
| 13L  | <b>Fire stopping installation detail</b><br>Supplier:<br>Reference:<br>Description:<br><br>Packers (h x d x t):<br><br>Gap width (t): | Craylon Limited<br>Blue 60<br>Gaps between the frame and the associated construction were maintained using low expansion fire rated graphite packers and filled with expanding foam.<br>100 x 15 x 1, 100 x 15 x 3, 100 x 15 x 5 combined to give required thickness.<br>18 top, 7.5 sides |

Key:

\* Nominal value

\*\* Sponsor declared value or detail, not verified by laboratory

‡ Constructional details omitted at the request of the Sponsor. Full details are held on file by the laboratory

## Appendix 1 Table 1b Right hand Leaf

| Item | Component   | Information  |
|------|---|--|
| 1R   | <b>Door frame</b><br>Supplier:<br>Description:<br><br>Fixing to supporting construction:<br><br>Density (kg/m <sup>3</sup> ):<br>Overall size (h x w x d):<br>Cross section size (h x d):   | Exitex Limited.<br>A 3 sided MDF frame with horizontal rebate joints at the top corners fixed with 2 No. Ø5 x 80 countersunk woodscrews at 65 centres and PVA adhesive**. 5 No. No.10 x 3" countersunk woodscrews set 200 from top and 140 from bottom with the remaining 3 No equally spaced on the jambs.<br>720 minimum**<br>2078 x 992 x 100 x 30<br>30 x 100  |
| 2R   | <b>Stops</b><br>Supplier:<br>Description:<br><br>Density (kg/m <sup>3</sup> ):<br>Overall size (w x d):   | Exitex Limited.<br>Butt jointed MDF stops fixed with 38mm x 16swg brads at 200* centres.<br>720 minimum**<br>12 x 31   |
| 3R   | <b>Leaf</b><br>Supplier:<br>Manufacturer:<br>Type:<br><br>Description:<br>Overall size (h x w x t):<br>Weight (kg):<br>Sub-components:<br>Core:<br>Type:<br>Overall size((h x w x t):<br>Top/bottom rail - inner:<br>Description:<br><br>Overall size (h x w x t):<br>Density (kg/m <sup>3</sup> ):<br>Top/bottom rail - outer:<br>Description:<br><br>Overall size (h x w x t):<br>Density (kg/m <sup>3</sup> ):<br>Stiles:<br>Description:<br>Overall size (h x w x t): | Exitex Limited.<br>Jeld Wen<br>F30RRO BTN 2040x926 MZF1 10/05/16 CF160 A4499758<br>6 panel FD30 leaf with moulded skins as shown in Figures 5 to 8.<br>2040 x 925 x 44 (to 23 at fielded areas)<br>38.3 (with ironmongery)<br><br>Particle board** machined to form panel profiles.<br>1896 x 861 x 38<br><br>Particle board** oriented 90° to core and adhered to core using PVA adhesive**.<br>35± x 861 x 38<br>Not declared*<br><br>Softwood** adhered to inner rail using PVA adhesive**.<br>27±x 861 x 38<br>Not declared*<br><br>Softwood** adhered to core using PVA adhesive**.<br>2040 x 31 x 38 hanging<br>2040 x 33 x 38 closing |

| Item                     | Component  | Information   |
|--------------------------|--|---|
| <b>3R</b><br><b>cont</b> | <p>Density (kg/m<sup>3</sup>):</p> <p>Moulded skin:</p> <p>Description:</p> <p>Thickness (t):</p> <p>Density (kg/m<sup>3</sup>):</p>   | <p>Not declared*</p> <p>Hardboard** adhered to core using PVA adhesive**.</p> <p>3</p> <p>Not declared*</p>   |
| <b>4R</b>                | <p><b>Hinges</b></p> <p>Manufacturer:</p> <p>Type:</p> <p>Material:</p> <p>Number:</p> <p>Location:</p> <p>Blade size (h x w x t):</p> <p>Knuckle size (Ø):</p> <p>Fixings (Ø x l):</p>  | <p>Hoppe</p> <p>Arrone AR8582-SSS butt hinge with concealed bearings.</p> <p>Stainless steel.</p> <p>3</p> <p>Set at 150, 930 and 1708 from the top of the leaf to the top of the blade.</p> <p>102 x 29 x 3.</p> <p>13.5.</p> <p>4 No Ø4.9 x 30 countersunk stainless steel wood screws per blade.</p>   |
| <b>5R</b>                | <p><b>Closer</b></p> <p>Manufacturer:</p> <p>Reference:</p> <p>Description:</p> <p>Overall size (l x h x d):</p>   | <p>Hoppe</p> <p>Arrone size 3 AR 450 SE</p> <p>A scissor arm closer with mild steel arms and aluminium body incorporating steel components fitted to the exposed face of both leaves positioned in accordance with the manufacturer's instructions using 2No. Ø4.8 x 27 long steel pan head screws to the frame and 4No.Ø5.4 x 32 long steel raised countersunk screws to the leaf.</p> <p>180 x 44 x 64</p>  |
| <b>6R</b>                | <p><b>Latch</b></p> <p>Supplier:</p> <p>Part Number:</p> <p>Description:</p> <p>Overall size:</p> <p>Body (h x w x d):</p> <p>Forend (h x d x t):</p> <p>Forend cover (h x d x t):</p> <p>Strike (h x d x t):</p> <p>Strike box (h x w x d):</p> | <p>Zoo Hardware Ltd</p> <p>CE1121</p> <p>A mainly steel cylinder mortice latch fitted central to the leaf depth such that the centre line of the spindle is 950 above the bottom of the leaf and affixed through the steel forend using 2No. steel countersunk woodscrews. A steel strike was fitted to the jamb to suit the position of the latch and affixed using 2No. steel raised countersunk woodscrews.</p> <p>23 x 60 x 15</p> <p>60 x 21.5 x 1.5</p> <p>60 x 25 x 1.1</p> <p>65 x 41 x 1.1, including a tongue of 40 x 16.</p> <p>58 x 14 x 23.5 plastic</p> |
| <b>7R</b>                | <p><b>Handleset</b></p> <p>Manufacturer:</p> <p>Reference:</p>   | <p>M Marcus</p> <p>Sorrento SC-4692-APMercury</p>   |

| Item                     | Component   | Information  |
|--------------------------|---|--|
| <b>7R</b><br><b>cont</b> | Description:<br><br>Overall Size:<br>Handle (Ø x l):<br>Rose cover (Ø x d x t):   | Oval tube lever handle, aluminium. Affixed to leaf with 2No. countersunk steel screws through backplate and 2No. through screws.<br><br>26 x 123<br>53 x 10 x 1.4  |
| <b>8R</b>                | <b>Intumescent – frame</b><br>Manufacturer:<br>Reference:<br>Description:<br><br>Location:<br>Overall Size:                           | Exitex Limited<br>FO104<br>A strip of graphite-based intumescent in a PVC casing with self-adhesive tape on one side. It is fully interrupted at the hinges and at the strike.<br>Positioned 15mm from exposed face.<br>10 x 4   |
| <b>9R</b>                | <b>Intumescent – hinge</b><br>Supplier:<br>Reference:<br>Description:<br><br>Overall size (t):  | Exitex Limited<br>Exi-Fire hinge pads<br>A graphite based intumescent fitted beneath each blade<br>1   |
| <b>10R</b>               | <b>Intumescent – latch</b><br>Supplier:<br>Reference:<br>Description:<br><br>Overall size (t):  | Exitex Limited<br>Exi-Fire latch protection<br>A graphite based intumescent wrapped around body of latch.<br>1   |
| <b>11R</b>               | <b>Intumescent – strike and forend</b><br>Supplier:<br>Reference:<br>Description:<br><br>Thickness (t):                               | Exitex Limited<br>Exi-Fire<br>A graphite based intumescent under strike and forend and wrapped around body of strike box.<br>1   |
| <b>12R</b>               | <b>Fire stopping installation detail</b><br>Supplier:<br>Reference:<br>Description:<br><br>Packers (h x d x t):<br><br>Gap width (t): | Craylon Limited<br>Blue 60<br>Gaps between the frame and the associated construction were maintained using low expansion fire rated graphite packers and filled with expanding foam.<br>100 x 15 x 1, 100 x 15 x 3, 100 x 15 x 5 combined to give required thickness.<br>18 top, 7.5 sides |


Key:

\* Nominal value


\*\* Sponsor declared value or detail, not verified by laboratory

‡ Constructional details omitted at the request of the Sponsor. Full details are held on file by the laboratory


**Appendix 1 Figure 1 – Elevation left hand doorset – unexposed face  
inc. hidden detail**



Appendix 1 Figure 2 – Section A – A




Appendix 1 Figure 3 – Section B – B







Appendix 1 Figure 4 – Section C – C




**Appendix 1 Figure 5 – Elevation right hand doorset – unexposed face  
inc. hidden detail**




Appendix 1 Figure 6 – Section D – D



Appendix 1 Figure 7 – Section E – E



Appendix 1 Figure 8 – Section F – F



## APPENDIX 2 PHOTOGRAPHS

### Appendix 2.1 Pre-test photos

Photo 2.1.1 – Left hand doorset



Photo 2.1.2 – Left hand doorset



Photo 2.1.3 – Left hand doorset



Photo 2.1.4 – Left hand doorset



Photo 2.1.5 – Left hand doorset



Photo 2.1.6 – Left hand doorset





**Photo 2.1.7 – Right hand doorset**



**Photo 2.1.8 – Right hand doorset**



**Photo 2.1.9 – Right hand doorset**




**Photo 2.1.10 – Right hand doorset**



**Photo 2.1.11 – Right hand doorset**



**Photo 2.1.12 – Right hand doorset**



**Photo 2.1.13**





## Appendix 2.2 During test photos

Photo 2.2.1



Photo 2.2.2





Photo 2.2.3



Photo 2.2.4



Photo 2.2.5





## Appendix 2.3 Post test photos

Photo 2.3.1





Photo 2.3.2



APPENDIX 3 POSITIONING OF INSTRUMENTATION



## APPENDIX 4 RECORDED THERMOCOUPLE DATA

| Time | Chan 16 | Chan 17 | Chan 18 | Chan 19 | Chan 20 | Chan 21 | Chan 22 |
|------|---------|---------|---------|---------|---------|---------|---------|
| min  | °C      | °C      | °C      | °C      | °C      | °C      | °C      |
| 0    | 15      | 15      | 15      | 14      | 14      | 14      | 15      |
| 1    | 15      | 15      | 15      | 15      | 15      | 15      | 15      |
| 2    | 15      | 15      | 15      | 15      | 15      | 15      | 15      |
| 3    | 15      | 15      | 15      | 15      | 15      | 15      | 15      |
| 4    | 15      | 15      | 15      | 15      | 14      | 14      | 15      |
| 5    | 15      | 15      | 15      | 15      | 15      | 15      | 15      |
| 6    | 16      | 15      | 15      | 15      | 15      | 15      | 15      |
| 7    | 17      | 15      | 15      | 15      | 15      | 15      | 15      |
| 8    | 18      | 15      | 15      | 15      | 15      | 15      | 16      |
| 9    | 19      | 16      | 15      | 15      | 16      | 15      | 16      |
| 10   | 20      | 17      | 16      | 16      | 17      | 15      | 16      |
| 11   | 22      | 18      | 17      | 17      | 19      | 15      | 16      |
| 12   | 24      | 19      | 19      | 20      | 21      | 15      | 17      |
| 13   | 27      | 22      | 22      | 23      | 23      | 15      | 17      |
| 14   | 30      | 24      | 24      | 26      | 26      | 15      | 18      |
| 15   | 33      | 28      | 27      | 29      | 29      | 16      | 18      |
| 16   | 37      | 31      | 29      | 31      | 31      | 16      | 18      |
| 17   | 39      | 34      | 32      | 34      | 34      | 16      | 19      |
| 18   | 42      | 38      | 34      | 37      | 36      | 16      | 20      |
| 19   | 45      | 41      | 37      | 39      | 39      | 17      | 20      |
| 20   | 47      | 44      | 39      | 42      | 41      | 17      | 21      |
| 21   | 49      | 47      | 41      | 44      | 43      | 17      | 21      |
| 22   | 51      | 49      | 43      | 46      | 45      | 17      | 21      |
| 23   | 53      | 51      | 45      | 48      | 47      | 17      | 22      |
| 24   | 55      | 54      | 47      | 49      | 49      | 17      | 23      |
| 25   | 56      | 56      | 49      | 51      | 51      | 18      | 24      |
| 26   | 58      | 58      | 51      | 53      | 53      | 18      | 24      |
| 27   | 60      | 60      | 53      | 55      | 55      | 18      | 25      |
| 28   | 61      | 62      | 55      | 56      | 56      | 19      | 25      |
| 29   | 63      | 63      | 57      | 58      | 58      | 19      | 25      |
| 30   | 65      | 65      | 59      | 60      | 60      | 19      | 26      |
| 31   | 66      | 66      | 61      | 61      | 61      | 20      | 27      |
| 32   | 67      | 68      | 63      | 63      | 63      | 21      | 29      |
| 33   | 68      | 69      | 64      | 64      | 64      | 21      | 29      |
| 34   | 69      | 70      | 66      | 65      | 66      | 22      | 31      |
| 35   | 70      | 71      | 67      | 66      | 67      | 22      | 32      |
| 36   | 72      | 73      | 69      | 68      | 69      | 23      | 33      |
| 37   | 73      | 74      | 70      | 69      | 69      | 24      | 35      |

| Time | Chan 23 | Chan 24 | Chan 25 | Chan 26 | Chan 27 | Chan 28 | Chan 29 |
|------|---------|---------|---------|---------|---------|---------|---------|
| min  | °C      | °C      | °C      | °C      | °C      | °C      | °C      |
| 0    | 14      | 14      | 14      | 15      | 15      | 15      | 14      |
| 1    | 15      | 15      | 15      | 15      | 15      | 15      | 15      |
| 2    | 15      | 15      | 15      | 15      | 15      | 15      | 14      |
| 3    | 16      | 15      | 15      | 15      | 15      | 15      | 15      |
| 4    | 15      | 15      | 15      | 15      | 16      | 16      | 15      |
| 5    | 15      | 28      | 22      | 15      | 16      | 16      | 15      |
| 6    | 16      | 51      | 36      | 17      | 16      | 16      | 15      |
| 7    | 15      | 50      | 39      | 18      | 16      | 16      | 15      |
| 8    | 15      | 48      | 40      | 19      | 16      | 16      | 15      |
| 9    | 15      | 47      | 42      | 21      | 16      | 16      | 15      |
| 10   | 15      | 48      | 44      | 23      | 17      | 16      | 16      |
| 11   | 15      | 49      | 47      | 25      | 18      | 17      | 17      |
| 12   | 16      | 52      | 51      | 27      | 20      | 19      | 19      |
| 13   | 16      | 54      | 54      | 30      | 23      | 21      | 21      |
| 14   | 16      | 57      | 57      | 34      | 26      | 24      | 23      |
| 15   | 16      | 60      | 60      | 37      | 30      | 26      | 26      |
| 16   | 16      | 64      | 63      | 41      | 34      | 29      | 29      |
| 17   | 16      | 67      | 65      | 44      | 37      | 32      | 31      |
| 18   | 17      | 71      | 68      | 47      | 41      | 35      | 34      |
| 19   | 17      | 74      | 71      | 49      | 44      | 37      | 36      |
| 20   | 17      | 77      | 73      | 51      | 48      | 40      | 39      |
| 21   | 17      | 79      | 76      | 54      | 50      | 42      | 42      |
| 22   | 17      | 80      | 78      | 56      | 53      | 44      | 44      |
| 23   | 18      | 82      | 81      | 57      | 55      | 47      | 46      |
| 24   | 18      | 84      | 84      | 59      | 57      | 49      | 48      |
| 25   | 19      | 86      | 86      | 61      | 60      | 51      | 50      |
| 26   | 19      | 89      | 89      | 62      | 61      | 53      | 52      |
| 27   | 19      | 91      | 90      | 64      | 63      | 54      | 54      |
| 28   | 20      | 93      | 92      | 65      | 64      | 56      | 56      |
| 29   | 20      | 96      | 94      | 67      | 65      | 58      | 58      |
| 30   | 20      | 100     | 96      | 68      | 66      | 59      | 60      |
| 31   | 20      | 110     | 100     | 69      | 67      | 61      | 62      |
| 32   | 21      | 124     | 106     | 71      | 69      | 63      | 64      |
| 33   | 21      | 135     | 114     | 72      | 70      | 64      | 65      |
| 34   | 22      | 146     | 125     | 73      | 71      | 66      | 66      |
| 35   | 23      | 158     | 138     | 66      | 72      | 67      | 68      |
| 36   | 23      | 171     | 153     | 66      | 73      | 69      | 65      |
| 37   | 24      | 185     | 169     | 68      | 74      | 70      | 62      |

| Time | Chan 30 | Chan 31 | Chan 32 | Chan 33 | Chan 34 | Chan 35 |
|------|---------|---------|---------|---------|---------|---------|
| min  | °C      | °C      | °C      | °C      | °C      | °C      |
| 0    | 14      | 14      | 15      | 14      | 14      | 14      |
| 1    | 15      | 15      | 15      | 15      | 15      | 14      |
| 2    | 15      | 15      | 15      | 15      | 14      | 15      |
| 3    | 16      | 15      | 16      | 15      | 14      | 15      |
| 4    | 16      | 15      | 16      | 15      | 15      | 15      |
| 5    | 16      | 15      | 18      | 15      | 21      | 19      |
| 6    | 16      | 15      | 20      | 15      | 38      | 30      |
| 7    | 15      | 15      | 20      | 15      | 41      | 33      |
| 8    | 15      | 15      | 20      | 15      | 42      | 35      |
| 9    | 16      | 15      | 23      | 15      | 44      | 36      |
| 10   | 17      | 15      | 22      | 15      | 47      | 39      |
| 11   | 19      | 15      | 22      | 15      | 51      | 43      |
| 12   | 21      | 15      | 23      | 15      | 54      | 47      |
| 13   | 23      | 15      | 23      | 15      | 57      | 51      |
| 14   | 26      | 16      | 23      | 15      | 61      | 55      |
| 15   | 29      | 16      | 23      | 15      | 64      | 58      |
| 16   | 31      | 16      | 23      | 16      | 68      | 61      |
| 17   | 34      | 16      | 23      | 16      | 71      | 65      |
| 18   | 37      | 17      | 24      | 16      | 74      | 69      |
| 19   | 39      | 17      | 24      | 16      | 77      | 72      |
| 20   | 41      | 18      | 24      | 16      | 79      | 75      |
| 21   | 43      | 18      | 25      | 16      | 81      | 78      |
| 22   | 45      | 18      | 25      | 16      | 84      | 81      |
| 23   | 47      | 18      | 26      | 17      | 86      | 83      |
| 24   | 49      | 19      | 28      | 17      | 88      | 87      |
| 25   | 51      | 19      | 28      | 17      | 91      | 90      |
| 26   | 52      | 20      | 30      | 18      | 93      | 92      |
| 27   | 54      | 20      | 32      | 18      | 94      | 93      |
| 28   | 56      | 20      | 33      | 18      | 96      | 94      |
| 29   | 57      | 21      | 36      | 19      | 98      | 96      |
| 30   | 59      | 21      | 37      | 19      | 101     | 99      |
| 31   | 61      | 21      | 39      | 19      | 109     | 107     |
| 32   | 63      | 22      | 41      | 20      | 120     | 118     |
| 33   | 64      | 23      | 42      | 20      | 132     | 130     |
| 34   | 66      | 24      | 43      | 21      | 145     | 141     |
| 35   | 67      | 24      | 43      | 21      | 159     | 152     |
| 36   | 68      | 25      | 45      | 22      | 172     | 165     |
| 37   | 70      | 26      | 47      | 22      | 187     | 177     |

\* Thermocouple malfunction